



Jim Doyle, Governor
Mary P. Burke, Secretary

June 15, 2005

GROVE CONCRETE & SUPPLY INC.
PAUL MILLER, JR.
18426 DURAND AVE
PO BOX 363
UNION GROVE WI 53182

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: GROVE CONCRETE & SUPPLY INC.
Product Name: NIBBLER JR.
Model Number(s): 1195/321-2 COMPARTMENT
Product File No: 20050271

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2010.

This approval is contingent upon compliance with the following stipulation(s):

- The manhole cover installed above the Nibbler Jr. must be installed so that it terminates at or above grade.
- This tank must only be used in conjunction with the Nibbler Jr. sewage treatment apparatus and in accordance with the Nibbler Jr.'s product approval stipulations.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on INSERT DATE under product file number 20001014.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20001014

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

GROVE CONCRETE & SUPPLY INC.

Page 2

June 15, 2005

Sincerely,

Lee E. Finley, Jr.

Bureau of Integrated Services

Department of Commerce

Phone (608) 261-0450

Fax (608) 267-9566

Email lfenley@commerce.state.wi.us